# Method for determining optimal overhaul service of centrifugal and axial pumps

*Bakhtiyor* Uralov<sup>1</sup>, *Sobir* Eshev<sup>2</sup>, *G*. Khakimova<sup>3</sup>, *Sh*. Mutalov<sup>5</sup>, *I*. Raimova<sup>1, 4</sup>, *D*. Arzieva<sup>5</sup> and *Mirsoxibjon* Salimbayev<sup>1</sup>

<sup>1</sup>"Tashkent Institute of Irrigation and Agricultural Mechanization Engineers" National Research University, Tashkent, Uzbekistan

<sup>2</sup>Karshi Engineering-Economics Institute, Karshi, Uzbekistan

<sup>3</sup>Tashkent Institute of Chemical Technology, Tashkent, Uzbekistan

<sup>4</sup>Research Institute of Irrigation and Water Problems, Tashkent, Uzbekistan

<sup>5</sup>Shahrisabz branch of Tashkent Institute of Chemical Technology, Shahrisabz, Uzbekistan

**Abstract.** The efficiency of pump operation mainly depends on the maximum permissible wear of the parts of their flow path. One of the factors determining the need for repair and restoration of centrifugal and axial pumps is the wear of parts that form the sealing and slotted gaps of the impellers. With an increase in the design clearances of the impellers, the leakage of liquid increases proportionally, and this worsens the energy performance of the pumps and, accordingly, leads to an increase in operating costs. At certain clearance values, the costs reach such a value that the pump operation becomes impractical. Therefore, when assessing the pump's performance, it is important to establish the wear limits of its parts. About a machine part, the limit state is a state in which its further operation is impossible due to an unrecoverable decrease in operating efficiency below the permissible level or the need for repair.

### **1** Introduction

Concerning vane pumps used in irrigation systems, the task of establishing allowable wear is mainly technical and economic. Taking into account the leading role of the size of the sealing and end gaps of the impellers of centrifugal and axial pumps with a decrease in energy performance, we have proposed a method for determining their optimal overhaul life based on a technical and economic comparison of options for reduced costs [1-6].

The equation expresses the given costs associated with the maintenance and operation of pumps:

$$K_{np} = K_i + C_i T \to \min \tag{1}$$

where,  $K_i$  is the costs associated with restoring the pump performance over time T; T is duration of operation of the pump, T = 1 year;  $C_i$  is costs associated with fluid leakage through sealing and slotted gaps of pump impellers

The annual cost to restore pump performance

<sup>©</sup> The Authors, published by EDP Sciences. This is an open access article distributed under the terms of the Creative Commons Attribution License 4.0 (https://creativecommons.org/licenses/by/4.0/).

$$K_i = K_l i \tag{2}$$

where *i* is the number of repairs;  $K_1$  is the cost of one repair. If during the year the pumping unit will be operated  $t_e$  hours, then:

$$i = \frac{t_e}{t_i} \quad and \quad K_i = K_1 \cdot \frac{t_e}{t_i} \tag{3}$$

where  $t_i$  is the duration of the pump operation up to a certain amount of wear of the parts that form the gaps of the impellers.

After appropriate processing of the experimental relations q=f(S) and q = f(t), obtained for a centrifugal pump 200 D-90 and an axial pump 05-35, for determining the total amount of leakage through the gap during time t, based on the compiled computer program, the following equations are obtained:

- for centrifugal pump:

$$\sum_{i=1}^{n} q_{i}t_{i} = \int_{0}^{t_{1}} 2.14 \cdot 10^{-2} dt + \int_{0}^{t_{1}} 3.96 \cdot 10^{-5} t \cdot dt - \int_{0}^{t_{1}} 6.6 \cdot 10^{-9} t^{2} \cdot dt$$
(4)

- for axial pump:

$$\sum_{i=1}^{n} q_{i}t_{i} = \int_{0}^{t_{1}} 1.17 \cdot 10^{-2} dt + \int_{0}^{t_{1}} 2.11 \cdot 10^{-5} t \cdot dt - \int_{0}^{t_{1}} 3.69 \cdot 10^{-9} t^{2} \cdot dt$$
(5)

According to the above formula (4), the reduced costs of CPR were determined by calculations through the computer programs. The extreme values of the curves Kpr=f (t) will correspond to the effective duration of the operation of the pumps and the maximum allowable values of the radial clearances of the impellers. When operating for six months during a year, the optimal overhaul life of a 200D-90 centrifugal pump  $t_0$ =810 h, the maximum allowable clearance S=1.9 mm, and for the PG-35MA axial pump  $t_0$ =1725 h and S=2.2 mm. This means that for the effective use of pumps for six months, it will be necessary to repair their parts at least 3-4 times [7-12].

#### 2 Research method

An analytical method for determining the wear of metals, a method for applying a polymer coating to metal surfaces, and generally accepted methods for laboratory and full-scale testing of centrifugal and axial pumps.

#### **Results of research and discussion**

The operating costs associated with the increase in sealing and slotted gaps of pump impellers are expressed as the energy spent on fluid leakage through these gaps in the following form:

$$C_i = e \cdot E_i = e \frac{9.81 \cdot H \cdot q_{av} \cdot t_i}{\eta_n \eta_{dv} \eta_{av} / \eta_0}$$
(6)

where e is cost of 1 kw/h of electricity;  $q_{av}$  is average gap leakage over time  $\Delta t = t_{i+1} - t_i$ ;  $\eta_p$ 

and  $\eta_{dv}$  are pump and motor efficiency;  $\eta_{av}$  is average volumetric efficiency of the pump for each certain period of time (ti+1 - ti.=  $\Delta$ t);  $\eta_0$  is initial volumetric efficiency of the pump.

The volumetric efficiency of the pump and its average values are determined by the expressions

$$\eta_0 = \frac{Q_t - q}{Q_t} \quad \text{and} \quad \eta_{av} = \frac{Q_t - q_{av}}{Q_t} \tag{7}$$

where  $Q_t$  is the theoretical flow of the pump; q is fluid leakage through the gap at a certain duration of operation t.

The formula determines the theoretical feed:

$$Q_t = Q + q \tag{8}$$

where Q is the initial actual flow of the pump.

Fluid leakage through gaps:

- for centrifugal pump:

$$q = 2\pi D_y \cdot S \cdot \mu \cdot \sqrt{2g \cdot \Delta H} \tag{9}$$

- for axial pump:

$$q = Z \cdot L \cdot S \cdot W_m \tag{10}$$

where L and Z are the length and number of blades, respectively.

Average leakage:

$$q_{av} = \frac{q_i + q_{i+1}}{2}$$
(11)

When calculating C by formula (6), the value  $\sum q_i t_i$  should be set. To do this, based on the results of a study of a centrifugal 200D - 90 pump and a 05–35 axial pump, the dependencies q=f(s) and q=f(t) were constructed (Fig. 1 and 2). After appropriate processing of the results, based on the compiled computer program, the following equations are established:

- for centrifugal pump:

$$q = 2.14 \cdot 10^{-2} + 3.96 \cdot 10^{-5} t - 6.6 \cdot 10^{-9} t^2$$
(12)

- for axial pump:

$$q = 1.17 \cdot 10^{-2} + 2.11 \cdot 10^{-5} \cdot t - 3.69 \cdot 10^{-9} \cdot t^2$$
(13)

To determine the total amount of leakage through the gap during time t, equations (12) and (13) must be integrated within the range from 0 to t1, i.e.:

$$\sum_{i=1}^{n} q_{i}t_{i} = \int_{0}^{t_{1}} 2.14 \cdot 10^{-2} dt + \int_{0}^{t_{1}} 3.96 \cdot 10^{-5} t \cdot dt - \int_{0}^{t_{1}} 6.6 \cdot 10^{-9} t^{2} \cdot dt \quad (14)$$

$$\sum_{i=1}^{n} q_i t_i = \int_0^{t_1} 1.17 \cdot 10^{-2} dt + \int_0^{t_1} 2.11 \cdot 10^{-5} t \cdot dt - \int_0^{t_1} 3.69 \cdot 10^{-9} t^2 \cdot dt$$
(15)

The final cost can be summarized as follows:

$$K_{av} = K_1 \frac{t_e}{t_i} + 9.81 \cdot e \cdot H \frac{\sum_{i=1}^n q_i t_i}{\eta_n \cdot \eta_{dv} \cdot \eta_{av} / \eta_0}$$
(16)

The numerical values of t,  $\Sigma q_i t_i$ , C, K and  $K_{pr}$  are determined, respectively, by formulas (14), (15), (6), and (16). Considering that these calculations require labor-intensive computations, computer programs have been used.



Fig. 1. Depending on the increase in leakage from the size of the sealing gap of the impeller (1) and the duration of operation (2) of the centrifugal pump



**Fig. 2.** Dependences of the increase in leakage on the size of the end clearance of the impeller (1) and the duration of operation (2) of the axial pump

Initial data for determining the optimal overhaul life of a centrifugal pump 200D-90:  $n_0=1480$  rpm;  $Q_t=0,2$  m<sup>3</sup>/c;  $P_t=90$  m,  $D_2=0,5$  m;  $D_y=0.23$  m; L=0.03 m;  $\eta_n=0.81$ ;  $\eta_{dv}=0.95$ ;  $t_c=5880$  h;  $K_1=43$  rub; e=0.02 rub; arrays  $t_1=0$ ,  $t_2=360$  h;  $t_3=720$  h;  $t_4=1080$  h;  $t_5=1800$  h;  $S_1=0.5 \cdot 10^{-3}$ m;  $S_2=1.2 \cdot 10^{-3}$ m;  $S_3=1.8 \cdot 10^{-3}$ m;  $S_4=2.4 \cdot 10^{-3}$ m;  $S_5=3 \cdot 10^{-3}$ m;  $\mu_1=0.524$ ;  $\mu_2=0.583$ ;  $\mu_3=0629$ ;  $\mu_4=0.661$ ;  $\mu_5=0676$ .

Initial data for determining the optimal overhaul life of the PG-35MA axial pump PG-35MA:  $Q_t=0.36 \text{ m}^3/\text{c}$ ; H=7 m; D=0.35 m; n=1200 of/min; Z=4; L=0.245m;  $\beta=24^0$ ;  $\eta_n=0.7$ ;  $\eta_{dv}=0.92$ ;  $t_e=5880$  h;  $K_1=51.3\text{py6}$ ; e=0.02 py6;  $t_1=0$ ;  $t_2=800$  h;  $t_3=1600$  h;  $t_4=2400$  h;  $t_5=3200$  h;  $t_6=4000$  h;  $t_7=4800$  h;  $S_1=0.5\cdot10^{-3}\text{m}$ ;  $S_2=1.25\cdot10^{-3}\text{m}$ ;  $S_3=1.91\cdot10^{-3}\text{m}$ ;  $S_4=2.53\cdot10^{-3}$ m;  $S_5=3.05\cdot10^{-3}\text{m}$ ;  $S_6=3.54\cdot10^{-3}\text{m}$ ;  $S_7=3.92\cdot10^{-3}\text{m}$ ;  $\mu_1=0.83$ ;  $\mu_2=0.845$ ;  $\mu_3=0.865$ ;  $\mu_4=0.895$ ;  $\mu_5=0.92$ ;  $\mu_6=0.98$ .

According to the above initial data, using special computer programs, calculations were made, and, based on the calculation results, graphs were drawn up, presented in Figures 3 and 4. values of radial clearances of impellers. The extreme values of the curves  $K_{np} = f_1(t) + f_2(t)$  will correspond to the effective duration of the operation of the pumps and the maximum allowable values of the radial clearances of the impellers [13-16].

When operating for six months (from 1.05 to 1.11) a year, the optimal overhaul life of a 200D-90 centrifugal pump is  $t_0=810$  h, and the maximum allowable clearance is S=1.9 mm, and for the PG-35MA axial pump is  $t_0=1725$  h and S=2.2 m. This means that for the effective use of pumps with a duration of operation of six months during the year, it is necessary to carry out current repairs of their parts at least 3-4 times. Since it is impractical to carry out repairs during the irrigation season, to increase the overhaul life of pumps, recommendations should be developed on the choice of their operating modes, improving structural elements, the use of wear-resistant materials for the manufacture of parts and modern methods for their restoration [17-22].



Fig. 3. Schedule for determining the optimal overhaul life of a centrifugal pump



Fig. 4. Schedule for determining the optimal overhaul life of an axial pump

## **3 Conclusions**

1. The proposed methods' calculations are compared with the data obtained due to measurements of pump parts of various standard sizes in operating conditions. The quantitative and qualitative correspondence of the calculation results with field data convinces us of the reliability of the hypothesis about the physical picture of the impact, which is the basis of the analytical wear equations.

2. Based on the methodology for calculating the wear intensity of pump parts, a method is proposed for determining their optimal overhaul life based on a technical and economic comparison of options at reduced costs. Calculations show that when operating for six months during a year, the optimal overhaul life of a 200D-90 centrifugal pump is 810 hours, and for a PG-35MA axial pump - 1725 hours. Therefore, it is required to develop various measures to increase the overhaul life of pumps.

3. The overhaul life of pumps can be increased by applying recommendations for choosing their operating modes, improving structural elements, using wear-resistant materials to manufacture parts, and using modern methods for their restoration.

## References

- 1. Mamajonov, M., Bazarov, D. R., Uralov, B. R., Djumabaeva, G. U., & Rahmatov, N. The impact of hydro-wear parts of pumps for operational efficiency of the pumping station. In Journal of Physics: Conference Series, Vol. 1425, No. 1, p. 012123. IOP Publishing. (2019).
- Uralov, B., Choriev, R., Maksudova, L., Sapaeva, M., Shernaev, A., & Nurmatov, P. Substantiation of the influence of the channel shape and the roughness of machine canals on the pressure loss of irrigation pumping stations. In IOP Conference Series: Materials Science and Engineering, Vol. 1030, No. 1, p. 012148. IOP Publishing. (2021).
- Eshev, S., Gaimnazarov, I., Latipov, S., Mamatov, N., Sobirov, F., & Rayimova, I. The beginning of the movement of bottom sediments in an unsteady flow. In E3S Web of Conferences, Vol. 263, p. 02042. EDP Sciences. (2021).

- Trulev, A., Verbitsky, V., Timushev, S., & Chaburko, P. Electrical submersible centrifugal pump units of the new generation for the operation of marginal and inactive wells with a high content of free gas and mechanical impurities. In IOP Conference Series: Materials Science and Engineering, Vol. 492, No. 1, p. 012041. IOP Publishing. (2019).
- Akanova, G., Sładkowski, A., Podbolotov, S., Kolga, A., & Stolpovskikh, I. Ways to reduce hydraulic losses in multistage centrifugal pumping equipment for mining and oil-producing industries. Scientific Bulletin of National Mining University, (6). (2021).
- 6. Gülich, J. F. Centrifugal pumps, Vol. 2. Berlin: Springer. (2008).
- Moloshnyi, O., Szulc, P., Moliński, G., Sapozhnikov, S., & Antonenko, S. The analysis of the performance of a sewage pump in terms of the wear of hydraulic components. In Journal of Physics: Conference Series, Vol. 1741, No. 1, p. 012015. IOP Publishing. (2021).
- 8. Shishlyannikov, D., Zvonarev, I., Rybin, A., Zverev, V., & Ivanchenko, A. Assessment of Changes in the Abrasiveness of Solid Particles in Hydraulic Mixtures Pumped with ESPs. Applied Sciences, 13(3), 1885. (2023).
- Bazarov, D. R., Norkulov, B. E., Kurbanov, A. I., Jamolov, F. N., & Jumabayeva, G. U. Improving methods of increasing reliability without dam water intake. In AIP Conference Proceedings, Vol. 2612, No. 1. AIP Publishing. (2023).
- Bazarov, D., Krutov, A., Sahakian, A., Vokhidov, O., Raimov, K., & Raimova, I. Numerical models to forecast water quality. In AIP Conference Proceedings, Vol. 2612, No. 1, p. 020001. AIP Publishing LLC. (2023).
- Uralov, B., Mutalov, S., Shakirov, B., Khakimova, G., Sirojov, B., & Raimova, I. Influence of hydroabrasive wear of impeller blades on head of centrifugal pump. In E3S Web of Conferences, Vol. 365, p. 03012. EDP Sciences. (2023).
- Burlachenko, A. V., Chernykh, O. N., Khanov, N. V., & Bazarov, D. R. Damping of increased turbulence beyond a deep and relatively short spillway basin. In AIP Conference Proceedings, Vol. 2612, No. 1. AIP Publishing. (2023).
- Uralov, B., Berdiev, S., Rakhmatov, M., Vokhidov, O., Maksudova, L., & Raimova, I. Theoretical models and dependences for calculating intensity of hydroabrasive wear of pump working parts. In E3S Web of Conferences, Vol. 365, p. 03019. EDP Sciences. (2023).
- Bazarov, D., Ahmadi, M., Ghayur, A., & Vokhidov, O. The Kabul River Basin-the source of the Naglu and other reservoirs. In E3S Web of Conferences, Vol. 365, p. 03047. EDP Sciences. (2023).
- Kan, E. K. The method of hydroecological monitoring for hydropower and hydraulic facilities of the Kashkadarya region of Uzbekistan. In AIP Conference Proceedings, Vol. 2612, No. 1. AIP Publishing. (2023).
- Kan, E., & Nasrulin, A. Technical and economic indicators of reconstructed irrigation pumping stations. In AIP Conference Proceedings, Vol. 2612, No. 1. AIP Publishing. (2023).
- Kan, E., & Vatin, N. Consumption of Irrigation Pumps Pumping Water with a High Content of Mechanical Impurities. In E3S Web of Conferences (Vol. 365, p. 03011). EDP Sciences. (2023).
- Norkulov, B. E., Nazaraliev, D. V., Kurbanov, A. I., Gayratov, S. S., & Shodiyev, B. Results of a study of severe deformation below the damless water intake section. In AIP Conference Proceedings, Vol. 2612, No. 1. AIP Publishing. (2023).

- Norkulov, B., Khujakulov, R., Kurbanov, I., Kurbanov, A., Jumaboyeva, G., & Kurbanov, A. Regime of deposition of sediments in the head settlement basin of the supply channel of pumping stations. In E3S Web of Conferences, Vol. 365, p. 03045. EDP Sciences. (2023).
- Bazarov, D., Vatin, N., Norkulov, B., Vokhidov, O., & Raimova, I. Mathematical Model of Deformation of the River Channel in the Area of the Damless Water Intake. In Proceedings of MPCPE 2021: Selected Papers, pp. 1-15. Cham: Springer International Publishing. (2022).
- Engel, R., Fibier, A., Heldt, J., & Ronecker, A. Hydro-Abrasive wear damage at reactor recirculation pump bearing journals. In Pressure Vessels and Piping Conference, Vol. 55065, pp. 137-144. American Society of Mechanical Engineers. (2012).
- 22. Höppel, H. W., Mughrabi, H., Sockel, H. G., Schmidt, S., & Vetter, G. Hydroabrasive wear behaviour and damage mechanisms of different hard coatings. Wear, 225, 1088-1099. (1999).